


NOTES:

- TO COMPLY WITH ANSI Z358.1-2004 FOR EMERGENCY EYEWASH AND EYE/FACE WASH:
 - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
 - EYEWASH OR EYE/FACE WASH SHALL BE POSITIONED WITH NOZZLES NOT LESS THAN 83.8 CM (33 IN.) AND NO GREATER THAN 114.3 CM (45 IN.) FROM SURFACE ON WHICH USER STANDS AND 15.3 CM (6 IN.) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.

- *THESE DIMENSIONS MAY VARY
±1/2" [12.7mm]



INFO FAX : 1-888-FAX-HAWS (1-888-329-4297)
1455 Kleppe Ln, Sparks NV, 89431
Phone: 775-359-4712 Fax: 775-359-7424
Haws Ag, Bachweg 3, CH-3401 Burgdorf, Switzerland
Haws Mfg Pte Ltd, 74 Sungai Kadut Loop, Singapore 729531
e-mail: Haws@hawsco.com website: www.hawsco.com

FOR NO. REVISION PER IR MODEL(S)
DRAWN: ECN: 4161 IR: 7460
DATE: 02/91 REV: 10
APPROVED: DATE: SCALE: 1:1
INFO FAX, DOC # 27460
DRAWING TYPE: INSTALLATION/FABRICK

0000080052.D
DRAWING NUMBER: 09206A00
SIZE: A SH: 1 OF 1